



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on June 18, 2018.

Water Icon Purification System CC
Unit H9 Pinelands Office Park
Ardeer Road, Modderfontein
1645 Johannesburg
South Africa
27 11 608 3345

Facility: Modderfontein, South Africa

Chemical/ Trade Designation	Function	Max Use	
Aluminum Chlorohydrate [AL]			
H6023	Coagulation & Flocculation	200	mg/L
Hydrance 6023	Coagulation & Flocculation	200	mg/L
Polymer Blends [AL] [PY]			
H6520	Coagulation & Flocculation	80	mg/L
H6540	Coagulation & Flocculation	66	mg/L
Hydrance 6520	Coagulation & Flocculation	80	mg/L
Hydrance 6540	Coagulation & Flocculation	66	mg/L

[AL] Based on an evaluation of health effects data, the level of aluminum in the finished drinking water shall not exceed 2 mg/L.

[PY] Polyamines Certified by NSF International comply with 40 CFR 141.111 requirements for percent monomer and dose.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.